



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur – 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com



TC - 15221

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2025/328	Report Issue Date :	11.07.2025
Invoice Details:	3163/Dt.07.07.2025/ Amt.Rs.1,652 /-		
ULR No:	TC152212500000163F		

Client Name & Address Contact No / Email.ID	: M/s.Jayanthi Public Senior Secondary School, S.F.No:66/2A, Jayanthi Gardens, Arulpuram, Tiruppur- 641 605.
Sample Name	: Water- Drinking
Sample Description	: Open Well Water
Sample Code No	: 328
Sample Submitted by	: Customer- Thiru.E.Rajamani.
Location & Date	: at M/s.Jayanthi Public Senior Secondary School & 07.07.2025.
Quantity of sample Received	: 2 Litre
Sample Container	: Plastic – Good condition.
Sample Condition on Receipt	: Good
Sample Received On	: 07.07.2025
Test Commenced on	: 07.07.2025
Test Completed on	: 08.07.2025
Environmental Condition	: 23.0°C-27.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	IS 3025 Part 11-2022	--	6.81	6.5-8.5	6.5-8.5
2	Total Alkalinity as CaCO ₃	IS 3025 Part 23-2023	mg/L	7	200	600
3	Total Hardness as CaCO ₃	IS 3025 Part 21-2009 (RA:2023)	mg/L	27	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA:2019)	mg/L	28	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24- Sec 1-2022	mg/L	< 5	200	400
6	Nitrate as NO ₃	IS 3025-Part 34- Sec 1-2023	mg/L	3	45	45
7	Fluoride as F	IS 3025-Part 60- Sec 1-2023	mg/L	< 0.2	1.0	1.5

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.
..... End of the Report.....

Reviewed & Authorised Signatory
B.George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur – 641602.

Phone: 0421 - 2245201

E-mail: labtpr@gmail.com

TEST REPORT


Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2025/328	Report Issue Date :	11.07.2025
Invoice Details:	3163/Dt.07.07.2025/ Amt.Rs.1,652 /-		

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Physical observation	--	Clear	-	-
2	Colour	IS 3025-Part 4	Hazen	< 2	5	25
3	Odour	IS 3025-Part 5	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025-Part 10	NTU	< 0.5	1	5
5	Total Dissolved Solids	IS 3025-Part 16	mg/L	71	500	2000
6	Conductivity	IS 3025-Part 14	μS/cm	102	-	-
7	P – Alkalinity as CaCO ₃	IS 3025-Part 23-1983	mg/L	NIL	-	-
8	Calcium as Ca	IS 3025-Part 40	mg/L	6	75	200
9	Magnesium as Mg	IS 3025-Part 46	mg/L	3	30	100
10	Iron as Fe	IS 3025-Part 53	mg/L	< 0.1	0.3	1
11	Manganese as Mn	IS 3025-Part 59	mg/L	< 0.05	0.1	0.3
12	Ammonia as NH ₃	IS 3025-Part 34	mg/L	< 0.1	0.5	0.5
13	Nitrite as NO ₂	IS 3025-Part 34	mg/L	< 0.01	-	-
14	Total Phosphate as PO ₄	IS 3025-Part 31	mg/L	< 0.1	-	-
15	Residual Chlorine	IS 3025-Part 26	mg/L	< 0.2	0.2	1.0
16	Fecal Coliform	IS 1622	CFU/100ml	0 / 100ml	0 / 100ml	0/100ml

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification with respect to above tested Parameters.

..... End of the Report.....


Reviewed & Authorised Signatory
B .George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue No./Date	01/01.07.2024	Amend. No/ Date	00/--	Page No	1 of 1
----------------	---------------	-----------------	-------	---------	--------



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN0012STUP01164

Issued Date : 07-07-2025

Organization Type : Educational Institutions

Expiry Date : 06-07-2026

Name of the Organization : JAYANTHI PUBLIC SENIOR
SECONDARY SCHOOL

Address : S.F.NO 66/2A, JAYANTHI GARDENS, ARULPURAM,
TIRUPPUR - 641605

I, K KRISHNAN owner/manager of the JAYANTHI PUBLIC SENIOR SECONDARY SCHOOL functioning as Educational Institutions located at Karaipudur in Tiruppur district hereby declare that

- This Self-Declared Sanitation certificate is valid from 07-07-2025 to 06-07-2026 and will be renewed every year prior to the expiry of the current certificate with updated information.
 - Our premises can accommodate 1500 people/pupils and has 16 urinals and 16 toilets which is proportionate to the number of users as per government norms.
 - 2 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
 - The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
 - There is no potential mosquito breeding area on the premises.
 - The premises have adequate drinking water fountains on each floor of the premises.
 - The self-declared certificate is displayed prominently on the premises along with the protocol
- The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN0012STUP01164 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பார்ப்பதற்கு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genulneness of the certificate can be verified by.

(a)Keying in the unique certificate number TN0012STUP01164 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.